

CARAVAN SITES AND CONTROL OF DEVELOPMENT ACT, 1960
Section 3

SITE LICENCE

To (1) Country Parks Limited
Greenacres Park, London Road, Meysey Hampton
Cirencester, Glos.

WHEREAS on the 9th day of November 19 89, you made application for a site licence in respect of land situate at (2) Greenacres Park, London Road, Meysey Hampton, Cirencester, Glos. (hereinafter called "the said land")

AND WHEREAS you are entitled to the benefit of permission (ref. No. CT708/E) for the use of the said land as a caravan site granted under Part III of the Town and Country Planning Act, 1971, otherwise than by a development order

NOW THEREFORE the (3) Cotswold District Council

HEREBY GRANT a site licence in respect of the said land pursuant to Section 3 of the Caravan Sites and Control of Development Act, 1960, subject to the following conditions, that is to say

See attached schedule

~~THIS LICENCE shall expire at the end of XXXXXXXXXXXXXXXXXXXX months/years from the XXXXXXXXXXXXXXXXXXXX day of XXXXXXXXXXXXXXXXXXXX 19 XXXXX~~

DATED this 3rd day of January, 19 90 .

Signed [Signature]
.....
.....(5)
.....Director of Housing and Environmental Services

- NOTES.
(1) Name and address of applicant, occupier of the land.
(2) Full description of the land to which the licence relates.
(3) Name of local authority.
(4) The same period should be stated as that specified in the planning permission: see s. 4 (1).
(5) Insert title of proper officer.

IT IS IMPORTANT THAT YOU SHOULD READ THE NOTES PRINTED ON THE BACK OF THIS FORM.

(AMENDED AT ENVIRONMENTAL SERVICES COMMITTEE ON 12.1.1993)

COTSWOLD DISTRICT COUNCIL
Caravan Sites & Control of Development Act 1960
Residential Caravan Site Licence Conditions

General

- 1(a) This licence applies to the site known as Greenacres Park, Meysey Hampton, for which planning permission reference number CT708/E (original) was granted on 23rd February 1961.

Site Boundaries

2. The boundaries of the site shall be clearly marked, for example by fences or hedges. In addition, the site owner shall give the local authority a plan of its layout. A 3 metre wide area shall be kept clear within the inside of all boundaries.

Density and Space between Caravans

3. Subject to the following variations, every caravan shall be not less than 6 metres from any other caravan which is occupied separately and not less than 2 metres from a road. The point of measurement for porches, awnings etc is the exterior cladding of the caravan.
- Porches may protrude 1m into the 6 metres and shall be of the open type.
 - Where awnings are used, the distance between any part of the awning and an adjoining caravan shall not be less than 3 metres. They should not be of the type which incorporates sleeping accommodation and they shall not face each other or touch.
 - Eaves, drainpipes and bay windows may extend into the 6 metre space provided the total distance between the extremities of 2 adjacent units is not less than 5.25 metres.
 - Where there are ramps for the disabled, verandahs and stairs extending from the unit, there shall be 4.5m clear space between them and two such items shall not face each other in any space. If they are enclosed, they will be considered as part of the unit and, as such, shall not intrude into the 6m space.
 - A garage, a shed or a covered storage space will be permitted between units only if it is of non-combustible construction (including non-combustible roof) and sufficient space is maintained around each unit so as not to prejudice means of escape in case of fire. Windows in such structures shall not face towards the units on either side. Car ports and covered walkways shall in no circumstances be allowed within the 6 metre space. For cars and boats between units, see condition relating to parking.

4. The density shall be consistent with safety standards and health and safety requirements. The gross density shall not exceed 50 caravans to the hectare, calculated on the basis of the useable area (i.e. excluding lakes, roads, communal services and other areas unsuitable for the siting of caravans) rather than the total site area.

Roads, gateways and footpaths

5. Roads and footpaths shall be designed to provide adequate access for fire appliances. Roads of suitable material shall be provided so that no caravan standing is more than 50 metres from a road. Where the approach to the caravan is across ground that may become difficult or dangerous to negotiate in wet weather, each standing shall be connected to a carriageway by a footpath with a hard surface. Roads shall not be less than 3.7 metres wide, or, if they form part of a clearly marked one way traffic system, 3 metres wide. Gateways shall be a minimum of 3.1 metres wide and have a minimum height clearance of 3.7 metres. Footpaths shall not be less than 0.75 metres wide. Roads shall have no overhead cables less than 4.5 metres above the ground. Roads and footpaths shall be suitably lit. Emergency vehicle routes within the site shall be kept clear of obstruction at all times.

Hard Standings

6. Every caravan shall stand on a concrete hard-standing which shall extend over the whole area occupied by the caravan placed upon it, and shall project a sufficient distance outwards from its entrances to enable occupants to enter and leave safely.

Fire Fighting Appliances

Fire Points

7. These shall be established so that no caravan or site building is more than 30 metres from a fire point. They shall be housed in a weather-proof structure, easily accessible and conspicuously marked "FIRE POINT".

Fire Fighting Equipment

8. Where water standpipes are provided and there is a water supply of sufficient pressure and flow to project a jet of water approximately 5 metres from the nozzle, such water standpipes shall be situated at each fire point. There shall also be a reel that complies with British Standard 5306 Part 1, with a hose not less than 30 metres long, having a means of connection to a water standpipe (preferably a screw thread connection) with a water supply of sufficient pressure and terminating in a small hand control nozzle. Hoses shall be housed in a box painted red and marked "HOSE REEL".
9. Where standpipes are not provided but there is a water supply of sufficient pressure and flow, fire hydrants shall be installed within 100 metres of every caravan standing. Hydrants shall conform to British Standard 750. Access to hydrants and other water supplies shall not be obstructed or obscured.

10. Where standpipes are not provided or the water pressure or flow is not sufficient, each fire point shall be provided with either water extinguishers (2 x 9 litre) or a water tank of at least 500 litres capacity fitted with a hinged cover, 2 buckets and 1 hand pump or bucket pump.

Fire Warning

11. A means of raising the alarm in the event of a fire shall be provided at each fire point. This could be by means of a manually operated sounder, e.g. metal triangle with a striker, gong or hand operated siren.

Maintenance

12. All alarm and fire fighting equipment shall be installed, tested and maintained in working order by a competent person and be available for inspection by, or on behalf of, the licensing authority. A log book shall be kept to record all tests and any remedial action.
13. All equipment susceptible to damage by frost shall be suitably protected.

Fire Notices

14. A clearly written and conspicuous notice shall be provided and maintained at each fire point to indicate the action to be taken in case of fire and the location of the nearest telephone. This notice shall include the following:-

"On discovering a fire:

- I. ensure the caravan or site building involved is evacuated.
- II. raise the alarm.
- III. call the Fire Brigade (the nearest telephone is sited ...).
- IV. attack the fire using the fire fighting equipment provided, if safe to do so.

It is in the interest of all occupiers of this site to be familiar with the above routine and the method of operating the fire alarm and fire fighting equipment."

Fire Hazards

15. Long grass and vegetation shall be cut at frequent and regular intervals where necessary to prevent it becoming a fire hazard to caravans, buildings or other installations on the site. Any such cuttings shall be removed from the vicinity of caravans. The space beneath and between caravans shall not be used for the storage of combustible materials.

Telephones

16. An immediately accessible telephone shall be available on the site for calling the emergency services. A notice by the telephone shall include the address of the site.

Storage of liquefied petroleum gas (LPG)

17. LPG storage supplied from tanks shall comply with Guidance Booklet HSG 34 "The Storage of LPG at Fixed Installations" or where LPG is supplied from cylinders, with Guidance Note CS4 "The Keeping of LPG in Cylinders and Similar Containers" as appropriate.

Exposed gas bottles or cylinders shall not be within the separation boundary of an adjoining unit.

LPG installations shall conform to British Standard 5482, "Code of Practice for domestic butane and propane gas burning installations, Part 2: 1977 Installations in Caravans and non-permanent dwellings".

Electrical Installations

18. Sites shall be provided with an electricity supply sufficient in all respects to meet all reasonable demands of the caravans situated on them.
19. Any electrical installations, which are not Electricity Board works and circuits subject to regulations made by the Secretary of State under section 16 of the Energy Act 1983 and section 64 of the Electricity Act 1947, shall be installed, tested and maintained in accordance with the provisions of the Institution of Electrical Engineers' (IEE) Regulations for Electrical Installations for the time being in force, and where appropriate, to the standard which would be acceptable for the purposes of the Electricity Supply Regulations 1988, Statutory Instrument 1988 No 1057.
20. Work on electrical installations and appliances shall be carried out only by competent persons such as the manufacturer's appointed agent, the electricity supplier, a professionally qualified electrical engineer, a member of the Electrical Contractors' Association, a contractor approved by the National Inspection Council for Electrical Installation Contracting, or a qualified person acting on behalf of one of the above. The installations shall be inspected periodically: under IEE Wiring Regulations, every year or such longer periods (not exceeding 3 years) as is considered appropriate in each case. When an installation is inspected, it shall be judged against the current regulations.

The inspector shall within 1 month of such an inspection, issue an inspection certificate in the form prescribed in the IEE Wiring Regulations which shall be retained by the site operator and displayed, supplemented or replaced by subsequent certificates, with the site licence. The cost of the inspection and report shall be met by the site operator or licence holder.

21. If an inspection reveals that an installation no longer complies with the regulations extant at the time it was first installed, any deficiencies shall be rectified. Any major alterations and extensions to an installation and all parts of the existing installation affected by them shall comply with the latest version of the IEE Wiring Regulations.

22. If there are overhead electric lines on the site, suitable warning notices shall be displayed at the entrance to the site and on supports for the line. Where appropriate, particular attention shall be drawn to the danger of masts of yachts or dinghies contacting the line.

Water Supply

23. All parks shall be provided with a water supply in accordance with statutory quality standards.

Drainage, sanitation and washing facilities

24. Satisfactory provision shall be made for foul drainage, either by connection to a public sewer or sewage treatment works or by discharge to a properly constructed septic tank or cesspool approved by the Department of Housing and Health.
25. Each caravan shall have its own piped water supply and water closet. Each caravan standing shall be provided with a connection to the foul drainage system; the connection shall be capable of being made air-tight when not in use.
26. Every site and every hard standing shall be provided with an adequate drainage system for the complete and hygienic disposal of foul, rain and surface water from the site, buildings, caravans, roads and footpaths.

Refuse Disposal

27. Every caravan standing shall have an adequate number of suitable non-combustible refuse bins with close-fitting lids or plastic bags. Arrangements shall be made for the bins to be emptied regularly. Where communal refuse bins are also provided these shall be of similar construction and housed within a properly constructed bin store.

Parking

28. One car only may be parked between adjoining caravans provided that the door to the caravan is not obstructed. Suitably surfaced parking spaces shall be provided where necessary to meet the additional requirements of the occupants and their visitors. Plastic or wooden boats shall not be parked between units.

Recreation Space

29. Where children live on the site, space equivalent to about one-tenth of the total area shall be allocated for children's games and/or other recreational purposes.

Notices

30. A suitable sign shall be prominently displayed at the site entrance indicating the name of the site.

31. A copy of the site licence with its conditions shall be displayed prominently on the site.
32. Notices and a plan shall be displayed on the site setting out the action to be taken in the event of an emergency. They shall show where the police, fire brigade, ambulance and local doctors can be contacted, and the location of the nearest public telephone. The notices shall give the name and location/telephone number of the site licence holder or his/her accredited representative. At sites subject to flood risk, warning notices shall be displayed giving advice about the operation of the flood warning system.
33. All notices shall be suitably protected from the weather and displayed where possible out of the direct rays of the sun, preferably in areas lit by artificial lighting.
34. Covered lockable storage space shall be provided for each caravan/mobile home standing. The structure shall be non-combustible and separate from the unit.